

DIST	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET NO.	TOTAL SHEETS

*Flornie E. Baultista*  
 REGISTERED CIVIL ENGINEER  
 No. CS4859  
 Exp. 6-30-18  
 CIVIL  
 STATE OF CALIFORNIA

January 20, 2017  
 PLANS APPROVAL DATE  
 THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.


TO ACCOMPANY PLANS DATED \_\_\_\_\_

**NOTES:**

- For longitudinal bar size, spacing and clearances, see Revised Standard Plan RSP P4.
- For tie bar and intermediate transverse bar details, see Revised Standard Plan RSP P16.
- Place intermediate transverse bars parallel to and in the same plane as transverse bars.
- Construct transverse joints at right angle to the longitudinal joints in adjacent CRCP. Space joints at no less than 10' intervals and no more than 14' intervals. Match location of JPCP transverse joint with CRCP transverse construction joint, expansion joint or wide flange beam. Omit dowel bars.
- For longitudinal contraction joint details, see Revised Standard Plan RSP P16.
- Do not construct longitudinal contraction joint when edge of new CRCP is less than 3'-3" from lane line.
- For additional longitudinal bars detail, see Detail A on Revised Standard Plan RSP P14.
- For longitudinal construction joint plan layout not shown, see Revised Standard Plan RSP P4. For tie bar details at longitudinal construction joint, see Revised Standard Plan RSP P16.
- For limits of rumble strips, see Project Plans.

**ABBREVIATION:**

D = Thickness of CRCP




**DETAIL A**

STATE OF CALIFORNIA  
 DEPARTMENT OF TRANSPORTATION  
**CONTINUOUSLY REINFORCED  
 CONCRETE PAVEMENT  
 (WIDENED LANE)  
 LANE AND SHOULDER  
 ADDITION OR REPLACEMENT**


NO SCALE

RSP P5B DATED JANUARY 20, 2017 SUPERSEDES STANDARD PLAN P5B  
DATED OCTOBER 30, 2015 - PAGE 137 OF THE STANDARD PLANS BOOK DATED 2015.

**REVISED STANDARD PLAN RSP P5B**



**PLAN**  
See Note 8



**SECTION Z-Z**

2015 REVISED STANDARD PLAN RSP P5B